



Certificate number: 2309784 (1)

Issued 20/09/2023

Expires 20/09/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Wirquin Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Wirquin Ltd.
Unit 3
Alpha Court
Throne
DN8 5TZ
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2309784

The following products belong to this certificate

PRODUCT DESCRIPTION Dual flush WC crop valve with an internal overflow. The valve is operated via a push button assembly for either full or reduced flush. For cold water use only. ATS3 – Without Production Surveillance.
MODEL(S) 10120440.
SIZE: 2" BSP(M).
SCOPE: Manufacturer recommended maximum working pressure: n/a & maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials not assessed.
MARKING Wirquin on body.
MATERIALS Non-metallic materials assessed (BS6920) not assessed.
BACKFLOW PROTECTION NOTES When used in a close coupled/low level WC suite, to form part of a Type AUK1 air gap arrangement, the distance between the invert of the overflow and the spillover level of the WC pan must be no less than 300 mm.
ADDITIONAL NOTES Opacity cannot be guaranteed.

Extra Notes