



Certificate number: 2508716 (1)

Issued 07/08/2025

Expires 07/08/2030

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### Wirquin Ltd

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

#### Certificate Issued to:

Unit 3  
Alpha Court  
Thorne  
DN8 5TZ  
United Kingdom



KUKreg4

# Product Certificate

Appendix to Certificate number: 2508716

---

The following products belong to this certificate

|   |
|---|
| <p>PRODUCT DESCRIPTION<br/>Range of syphon dual flush outlet flush valves.<br/>ATS3 – Without Production Surveillance.</p>  |
| <p>MODEL(S)<br/>Metro range:<br/>DSY0125<br/>7.5" METRO S/F SIPHON 2.25" C LINK</p> <p>DSY0225<br/>8" METRO SIPHON DUAL FLUSH</p> <p>DSY0275<br/>8.5" METRO SIPHON DUAL FLUSH</p> <p>DSY0325<br/>9" METRO SIPHON DUAL FLUSH</p> <p>DSY0425<br/>9.5" S/F METRO SIPHON 2.25" C LINK</p> <p>DSY0538<br/>10" METRO S/FLUSH SIPHON 4 3/8" C LINK</p> <p>DSY2138<br/>8.5 ELAN SYPHON 3.5" C LINK</p> <p>CF2611XX<br/>8" SYPHON 73mm HOLE 3 1/2" C LINK</p> <p>CF2614XX<br/>8.5" SYPHON 73mm HOLE 4" C LINK</p> <p>CF2618XX<br/>7.5" SIPHON 73mm HOLE 3 1/2" C LINK</p> <p>Metro Rapid oblong range:<br/>DSY8725<br/>7.5"SIPHON 2.25"C LINK</p> <p>DSY8825<br/>8"SIPHON 2.25"C LINK</p> <p>DSY8875<br/>8.5"SIPHON 2.25"C LINK</p> <p>DSY8925<br/>9"SIPHON 2.25"C LINK</p> <p>DSY9025<br/>9.5"SIPHON 2.25"C LINK</p> <p>DSY9138</p> |

# Product Certificate

Appendix to Certificate number: 2508716

|  |
|--|
| <p>10"SIPHON 4 3/8"C LINK</p> <p>DSY9238<br/>10.5"SIPHON 4 3/8"C LINK</p> <p>Metro Rapid Square range:<br/>DSY7925<br/>7.5"SIPHON 2.25"C LINK</p> <p>DSY8025<br/>8"SIPHON 2.25"C LINK</p> <p>DSY8125<br/>9"SIPHON 2.25"C LINK</p> <p>DSY8225<br/>9.5"SIPHON 2.25"C LINK</p> <p>Metro Rapid Round range:<br/>DSY7125<br/>7.5" SIPHON 2.25"C LINK</p> <p>DSY7225<br/>8"SIPHON 2.25" C LINK</p> <p>DSY7275<br/>8.5"SIPHON 2.25"C LINK</p> <p>DSY7325<br/>9"SIPHON 2.25"C LINK</p> <p>DSY7425<br/>9.5"SIPHON 2.25"C LINK</p> <p>DSY7538<br/>10"SIPHON 4 3/8"C LINK</p> <p>DSY7638<br/>10.5"SIPHON 4 3/8"C LINK</p> |
| <p>SIZE:<br/>See model</p>   |
| <p>SCOPE:<br/>Manufacturer recommended maximum working pressure open outlet use only &amp; maximum operating temperature cold water use only.<br/>Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.</p>  |
| <p>MARKING<br/>Derwent MacDee on body</p>  |
| <p>MATERIALS<br/>Non-metallic materials not assessed.</p>  |
| <p>BACKFLOW PROTECTION NOTES<br/>When used in a close coupled/low level WC suite, to form part of a Type AUK1 air gap arrangement, the distance between the invert of the overflow and the spillover level of the WC pan must be no less than 300 mm.</p>  |
| <p>ADDITIONAL NOTES<br/>All water contact &amp; exposed components satisfy opacity requirements<br/>Suitable for use in a WC suite, provided it forms an arrangement which meets the requirements of Type AUK1 and an</p>  |

## Product Certificate

Appendix to Certificate number: 2508716

---

appropriate WC performance specification. Please refer to the clarification of the requirements of the Water Supply(Water Fittings) Regulations, Byelaws in Scotland, as they apply to Type AUK1 air gaps in WC suites.

### Extra Notes